

Date: December 18, 2019

RE: Bob Marcello Baseball and Tennis Lighting – Request for information

Thank you for your interest in the Village's project. Highlighted responses to requests for information are listed below. Please note the list is a compilation of questions submitted from multiple Contractors and Suppliers.

Previous RFI responses and addenda can be viewed at: <http://www.royalpalmbeach.com/Bids>

Sincerely,

Adamo DiSisto, E.I.  
Project Engineer  
Office: (561) 790-5131  
Village of Royal Palm Beach  
Engineering Department  
1050 Royal Palm Beach Boulevard  
Royal Palm Beach, FL 33411  
[adisisto@royalpalmbeach.com](mailto:adisisto@royalpalmbeach.com)

**From:** Jason Newman <[info@janlightingsolutions.com](mailto:info@janlightingsolutions.com)>  
**Sent:** Monday, December 16, 2019 9:08 AM  
**To:** Jacqueline Davy <[JDavy@RoyalPalmBeach.com](mailto:JDavy@RoyalPalmBeach.com)>  
**Subject:** Re: Bob Marcello Baseball and Tennis Lighting

1. Will the city accept alternatives that are equivalent in all aspects of the poles, controls, and light fixtures?

In order to be accepted and listed as an approved alternate, the Village will need to review specification materials for the complete system, including poles, controls, light fixtures, and warranties to determine if the proposed alternate is equivalent. Please send such alternate descriptions and specification packages to [adisisto@royalpalmbeach.com](mailto:adisisto@royalpalmbeach.com).

**From:** Grant Pierce <[gpierce@BIRD-X.COM](mailto:gpierce@BIRD-X.COM)>  
**Sent:** Tuesday, December 17, 2019 2:56 PM  
**To:** Adamo DiSisto <[adisisto@RoyalPalmBeach.com](mailto:adisisto@RoyalPalmBeach.com)>  
**Subject:** RFI: Bob Marcello Baseball and Tennis Lighting

1. Drawings E-4.0, Note 4 and E-5.0, note 4 mention bird deterrents needing to be installed on light poles and crossarms. Can you please provide a product specification? We would recommend Bird-X Stainless Steel Spikes.

Bird-X Stainless Steel Spikes are an approved option for the bird deterrents called for in Note 4 on Sheets E-4.0 and E-5.0.