

Date: June 7, 2023

RE: Crestwood North Park, PR2102 – Request for information

Thank you for your interest in the Village's project. Highlighted responses to requests for information are listed below. Please note the list is a compilation of questions submitted from multiple Contractors and Suppliers.

Previous RFI responses and addenda can be viewed at: <http://www.royalpalmbeachfl.gov/rfps>

Sincerely,

Christopher Marsh, P.E.  
Village Engineer  
Office: (561) 790-5131  
Village of Royal Palm Beach  
Engineering Department  
1050 Royal Palm Beach Boulevard  
Royal Palm Beach, FL 33411  
[cmarsh@royalpalmbeach.com](mailto:cmarsh@royalpalmbeach.com)

**From:** Willard Grummert <[grummert@gmail.com](mailto:grummert@gmail.com)>  
**Sent:** Monday, June 5, 2023 3:36 PM  
**To:** Jacqueline Davy <[JDavy@royalpalmbeachfl.gov](mailto:JDavy@royalpalmbeachfl.gov)>  
**Cc:** Jeffrey Grummert <[jeff@aroundfloridainc.com](mailto:jeff@aroundfloridainc.com)>  
**Subject:** Re: Crestwood North Park

RFI #1

1 -Good Afternoon Jacqueline--Received, thank you. We're interested in bidding the GFRC Column Covers shown on the Pavilion and Restrooms. Page A1.1 shows the Pavilion columns and refers to Page A1.3 for cuts through the column covers. There was no Page1.3 in the set of drawings you sent to me. Please investigate and get us access to Page A1.3. Thank you.

**The column section is on sheet A3.0, detail 2.**

Date: June 12, 2023

**From:** Josh Della-Pietra <[Josh@RDPCConst.com](mailto:Josh@RDPCConst.com)>  
**Sent:** Thursday, June 8, 2023 1:47 PM  
**To:** Tim DeLand <[tdeland@royalpalmbeachfl.gov](mailto:tdeland@royalpalmbeachfl.gov)>  
**Subject:** RFI - Crestwood North Park

RFI #2

1. The plans show 2 hexagon shelters, 1 octagon and 1 rectangular. Sheet A1.1 shows specs on the hexagon and rectangular, but not on the octagon. Should we assume similar roof angles and entry heights for the octagon?

Sheet 1 of 10 lists the rectangle Shelter as Pavilion A, octagon shelter as Pavilion B and the hexagon shelters as Pavilion C. Sheet A1.1 lists the rectangle shelter as Pavilion B and the hexagon as Pavilion C, but does not show the octagon shelter or a designated Pavilion A.

**Refer to sheet A1.1 for hexagon 'C' and rectangular 'B' pavilions. No octagon shape.**

RFI #3

2. - Door schedule sheet A3.0 calls out to refer to Specifications section 08710 for hardware. Please post or email the hardware specs so we can price accordingly.  
- Door type A calls for Aluminum louver in door. Advise aluminum louver manufacturer with valid hurricane component test that can be used in a Hollow Metal door. Otherwise, Windstorm louver component tested will be STEEL per HM door Product approval (not aluminum).

**Owner to provide project specifications (Project Manual).  
Door louver to be HM not aluminum.**

RFI #4

3. Will equals need to be reviewed before bid time. This pertains to the site furnishings.

**Yes. Substitutions require review, by Owner, prior to bid**

From: Karl Severance <karl.severance@cooperlighting.com>  
Sent: Friday, June 9, 2023 10:18 AM  
To: Tim DeLand <tdeland@royalpalmbeachfl.gov>  
Subject: RE: RFI - Crestwood North Park

RFI #5

The bid documents reference an owner direct purchase of Musco Sports Lighting via a cooperative procurement contract. Is the Village of RPB entertaining other lighting systems that can be purchased via cooperative procurement as well? If so, since this purchase would be outside of the rest of the project, we'd like the opportunity to meet with you to discuss the project, our product offering, and how we meet project requirements.

**The Village is not interested in the lighting systems to be purchases by cooperative procurement at this time.**

From: Thomas Addoms <TAddoms@gatordock.com>  
Sent: Wednesday, June 7, 2023 3:36 PM  
To: Clerk's Office <Clerks\_Office@RoyalPalmBeach.com>  
Subject: Crestwood North Park - PR2102 - Request Approved Equal - Royal Palm Beach

RFI #6

please confirm the correct size:

C4/C18 call out 3x46'

C12/C19 call out 3x29'

The gangway length should be 43.5'

RFI #7

I would like to request Gator Dock and Bridge be approved equal for the commercial grade gangway

Gator dock may be used as an approved equal provided the products meet the specifications.