

Bidding Phase

Request For Information: RFI No. 02

Architects Project No.: 2021-0119

Date Of Issue 6/3/2022

Attn: ALL BIDDERS

1. Is the Drexel metal roof panel an acceptable product with same warranty and profile and 22ga?
Response: Yes, it will be considered, providing it meets all specifications and you can provide a similar color panel as specified.

2. A section talks about spray foam. Is this part of the scope of work?
Response: Yes. Refer to Note 5/A1.0, Detail6/A2.0 and Specifications 072119.

No drawings or specifications reissued with this RFI.

Issued By:

Robert E. Hill, RA

DHGA DESIGN - FL