## Village of Royal Palm Beach, Florida



10996 Okeechobee Boulevard Royal Palm Beach, Florida 33411
Telephone (561) 790-5122 Fax (561) 791-7075 E-mail: pwebster@royalpalmbeachfl.gov

Paul L. Webster, P.E., C.S.M. Director of Public Works

Canal Slope Stabilization PW1806

Response to RFI # 2

Issue Date: May 9, 2024

To All Bidders: Question received:

• Is it the intent to place the rip rap along the banks of the canal, including under the bridge, but not across the flat bottom of the canal?

## Response:

• Yes, it is the intention to place the rip-rap along the banks of the canal, including under the bridge, and not across the flat bottom of the canal.

Issued By:

Paul L. Webster, P.E., C.S.M. Director of Public Works